


No warranty is made by the BLM as to the accuracy, reliability, or completeness of these data for individual use or aggregate use with other data.
 BLM Winnemucca District Office
 5100 E. Winnemucca Blvd.
 Winnemucca, NV 89445
 April 17, 2013



Construction Noise from Proposed Action Gen-Tie and Tie Line Options

- Proposed Action Gen-Tie and Tie-Line 200-foot ROW
- Noise interval
- Project access road
- Town or city
- Geothermal lease area
- Interstate
- Township and range
- Surface Ownership
- Bureau of Land Management
- Private (includes county and city)

Noise contours based on an assumed noise generation of 95 dBA at 50 feet, which is maximum assumed noise during. These noise levels would be present intermittently over a period of approximately two days at any given location.

Although there are four candidate power plant locations, the East power plant location was selected for this analysis since the tie-line options for that plant site would come closer to the main cluster of bat roosts and hibernation locations than the other candidate plant sites.

Source: BLM 2013, TGP 2011



Figure 18